

THE CORPORATION OF THE CHISHOLM TOWNSHIP
CONTRACT NO. CH 2021-01
ALDERDALE ROAD RECONSTRUCTION

ADDENDUM NO. 1 TO CONTRACT

Tenderers are hereby advised of the following changes and/or clarifications for this tender:

1) FORM OF TENDER

Item 4 – Base Stabilization

The unit rate for payment will be based on square meters. Please change the reference to L.S. **and replace with m²**. The estimated quantity remains the same.

2) DIVISION “G” - SPECIAL PROVISIONS

Item 3 ii) – DOUBLE SURFACE TREATMENT

a) This Contract will not require the polymer additive to the HF-150. Therefore, the reference to HF150P shall be deleted and **replaced with HF-150**.

b) In addition, the Contract will not require Class 6 stones for all surface treatment work, but will require the use of Class 2 stone.

The Class 6 stone shall be deleted and **replaced with Class 2** stone.

Application Rates (ADDED for clarification)

The Contractor shall be responsible for determining application rates of both aggregate and emulsion and must provide the rates to the Owner in writing prior to the start of work.

2) DIVISION “F” – SPECIAL PROVISION


Item 1 and 2 referring to Subexcavation prior to granular and subexcavation for soft spots **may be removed from this tender** and therefore **do not require a bid price**. They are not identified in the form of tender and are unlikely to be used for this project.

The following addendum notice shall be signed and may be faxed at (705-724-5099 – Chisholm Township) or attached to the cover page of the submitted tender. The Municipality will also accept a signed e-mail copy of this addendum sent to antoine.boucher@eastferris.ca as an alternative.

Additional contact information

Antoine Boucher, Township Engineer
(705) 752-2740 (work)
(705) 475-2560 (cel)

END OF ADDENDUM NO. 1



Antoine C. Boucher, P. Eng.
Acting Municipal Engineer
Chisholm Township

Bidder's Signature